



NOTES:

1. ALL BENDS IN TYPE K COPPER PIPE SHALL BE MADE USING AN APPROPRIATE PIPE BENDING TOOL. THERE SHALL BE NO CRIMPS IN THE PIPE LINE.
2. WATER METER BOX INSTALLATION SHALL MAINTAIN A MINIMUM 18-INCH HORIZONTAL EDGE-TO-EDGE CLEARANCE FROM DRIVEWAYS AND/OR DRIVE PATHS, SIDEWALKS, BIKE PATHS, CURBING AND ADJACENT WATER METER BOXES UNLESS APPROVED OTHERWISE BY JCSA.
3. WATER METER RELOCATIONS SHALL REQUIRE A NEW TAP WHEN LANDSCAPING OR OTHER PHYSICAL FEATURES REQUIRE RELOCATION OF THE EXISTING SERVICE MORE THAN 5- FEET.
4. WATER SERVICE LINES SHALL BE PERPENDICULAR TO THE MAIN, EXCEPT IN CUL-DE-SACS.
5. JCSA WILL ALLOW 2-INCH SERVICE LINES TO TAP AT THE PIPE SPRINGLINE WITH A FULL SADDLE AS MANUFACTURED BY FORD METER BOX COMPANY MODEL FS303 OR APPROVED EQUAL.



TYPICAL WATER METER INSTALLATION

DWG.NO. W13.0	SCALE: NONE
DWN BY:	DATE:1-1-2002

REVISION DATE	COMMENT
JUNE 2004	ADDED NOTE 1 & CORPORATION STOP NOTE
JULY 2005	ADDED NOTES 2, 3 & 4
SEPT 2007	REVISED NOTE 2 & ADDED NOTE 5
JUNE 2011	REVISED METER BOX DRAWING